

Supplementary Information

Assessing the Feasibility of Gray, Blue, and Green Ammonia Production in Indonesia: A Techno-Economic and Environmental Perspective

Martin Tjahjono^a*, Isabella Stevani^a, Gracheilla A. Siswanto^a, Arief Adhitya^a, Iskandar Halim^b**

^aDepartment of Chemical and Food Processing, Calvin Institute of Technology, Jl. Industri Blok B14 Kav. 1, Kemayoran, Jakarta Pusat 10610, Indonesia. ^bInstitute of Sustainability for Chemicals, Energy and Environment (ISCE²), Agency for Science, Technology and Research (A*STAR), 1 Pesek Road, Jurong Island, Singapore 627833, Republic of Singapore.

Link of article

https://doi.org/10.14710/ijred.2023.58035

A. Definitions

a. Capacity factor

Plant's actual output or throughput over a period of time compared to its full capacity. The average capacity factor for an ammonia plant is 90%.

b. Discount rate

Rate of interest that is applied to the future cash flows of an investment to calculate its present value. In this case, the discount rate is assumed to be 8%.

- c. LHV of NG Thermal energy produced by the combustion of natural gas with energy losses consideration due to the vaporization of water. In this case, the LHV of NG is assumed to be 46.5 GJ/ton.
- d. MVC

Mechanical vapor compression is a method used to purify electrolyzer's feed water.

e. Balance of plant

Supporting components and auxiliary systems, including air system, flare system, drain system, interconnecting, and buildings.

f. Amortization

The cost for repayment of debt through periodic installments over a period of time. In this case, amortization occurs only for green ammonia due to the requirement to replace the electrolyzer's stack every 6 and 10 years for PEM and alkaline electrolyzers, respectively.

^{*}Corresponding e-mail: martin.tjahjono@calvin.ac.id

^{**}Corresponding e-mail: Iskandar_Halim@isce2.a-star.edu.sg

COLOR DICTIONARY Insert a number Choose from the dropdown Calculation result INPUT Ammonia type Green Electrolyzer Alkaline Hydro Green electricity source Annual plant capacity 730,000 ton NH₃/year Purge Gas 🔺 Capacity factor 90 % H₂ Recycle Discount rate (DR) 8.0 % IEAGHG, 2017 NG Fuel, LHV of NG 46.5 GJ/ton IEAGHG, 2017 Process Air Methanator (6) Compression (7) Water Natural gas (NG) cost 6.0 \$/GJ (LHV) ESDM Shifted Raw water cost 0.4 \$/m³ Primary Reformer (1) Secondary Syngas Cooling Unit (4) Ammonia Synthesis (8) CO Shifter (3 CO₂ Removal (5) Grid electricity cost options Manual input NG Fee Reformer (2) Grid electricity cost suggested 45.0 \$/MWh Perpres NH₃ CO₂ Grid electricity cost manual input 37.6 \$/MWh mmonia Coolin CO2 capture from boiler cost 70.0 \$/t CO2 captured Electricity • Raksajati Unit (9) CO₂ storage cost 10.8 \$/t CO2 stored IEAGHG, 2017 Liquid NH₃ CO2 penalty cost 90.0 \$/t CO2 emitted CO₂ Capture Unit (11) CO₂ Product Ammonia Storage (10) Individual average salary (AS) 9,730 \$/person Ţ Water, Decarbonized Flue Gas Energy setting (see Table 5) Following suggestion 33.38784 GJ/ ton NH3 Electricity suggested GJ/ ton NH3 Electricity manual input Do not enter 0 GJ/ ton NH3 NG feedstock suggested NG feedstock manual input GJ/ ton NH3 Do not enter NG fuel suggested 0 GJ/ ton NH3 NG fuel manual input Do not enter GJ/ ton NH3

-

-


B. Graphical User Interface of Spreadsheet-Based Decision Support System


Variables	Value	Unit
Electricity	21,935,811	GJ/yr
NG feed	-	GJ/yr
NG fuel	-	GJ/yr
TOTAL ENERGY CONSUMPTION	21,935,811	GJ/yr
Raw feed and process water	1,771,929	m³/yr
CO2e produced from onsite reformer	-	ton CO2e/yr
CO2e produced from onsite boiler	-	ton CO2e/yr
CO2e captured from onsite reformer	-	ton CO2e/yr
CO2e captured from onsite boiler	-	ton CO2e/yr
CO ₂ e stored onsite	-	ton CO2e/yr
CO ₂ e released	-	ton CO2e/yr
Number of labor (NL)	55	

-

-

CAPITAL COST (CAPEX)	Cost
HB reactor	\$ 197,889,120
SMR	\$ -
Electrolyzer modules	\$ 370,666,667
MVC	\$ 89,333,333
ASU	\$ 139,425,520
CO ₂ capture unit	\$ -
CO ₂ compression unit	\$ -
PEC (Purchased Equipment Cost)	\$ 797,314,640
Utilities and BoP	\$ 478,388,784
TIC (Total Installed Cost)	\$ 1,275,703,424
Contingency	\$ 255,140,685
TPC (Total Plant Cost)	\$ 1,530,844,109
Spare parts cost (SPC)	\$ 7,654,221
Start-up cost (SUC)	\$ 43,749,871
Owner's cost (OC)	\$ 107,159,088
Interest during construction (IDC)	\$ 122,467,529
Working capital (WC)	\$ 55,812,025
TCR (Total Capital Requirement)	\$ 1,867,686,842
OPERATIONAL COST (OPEX)	
Direct labor (DL)	\$ 535,150
Maintenance (M)	\$ 45,925,323
Insurance & local taxes (ILT)	\$ 15,308,441
Administration and general overheads (AGO)	\$ 5,671,584
Amortization (A)	\$ 16,680,000
Subtotal fixed operational cost (FOC)	\$ 84,120,498
NG feedstock and fuel (NG)	\$ -
Electricity from grid (E)	\$ 229,107,358
Raw feed and process water	\$ 708,772
Catalysts and chemicals (CC)	\$ 16,047,997
CO ₂ capture	\$ -
CO ₂ storage	\$ -
CO ₂ penalty	\$ -
Subtotal variable operational cost (VOC)	\$ 245,864,126
Total Operational Cost (TOC)	\$ 329,984,624
LCOA	\$ 502





C. Parameters and Formula for Calculating LCOA

The details of LCOA calculation starting from the energy consumptions, emissions, capital cost, and operational cost for each scenario are provided in **Table S1, S2, S3, and S4**. These calculations are adapted from IEAGHG (2017) and Rivarolo *et al.* (2019).

Unit Operation	Gray	Blue
Haber-Bosch (HB) Reactor	\$208,427,670 1,350 (tpd) × C (tpd)	\$211,434,097 1,350 (tpd) × C (tpd)
Steam Methane Reforming (SMR)	$\frac{\$304,248,487}{1,350 \text{ (tpd)}} \times \text{C (tpd)}$	\$308,564,977 1,350 (tpd) × C (tpd)
Utilities and Balance of Plant (BoP)	\$55,774,000 1,350 (tpd) × C (tpd)	\$59,696,000 1,350 (tpd) × C (tpd)
CO ₂ Capture Unit	-	\$48,360,000 1,350 (tpd) × C (tpd)
CO ₂ Compression Unit	-	\$10,400,000 1,350 (tpd) × C (tpd)

Table S1. Major installed cost components for gray and blue ammonia production.

Note: The installed cost of each major component is approximated to be proportional to the production capacity (C). We have used a reference capacity of 1350 tons ammonia per day (tpd) (IEAGHG, 2017).

Unit Operation	Alkaline	PEM
Mechanical Vapor Compression (MVC) ^a	$MVC = \frac{\$13,400,000}{300 \text{ (tpd)}} \times C \text{ (tpd)}$	$MVC = \frac{\$11,960,000}{300 \text{ (tpd)}} \times C \text{ (tpd)}$
Electrolyzer Modules (EM) ^a	$EM = \frac{\$139,000,000}{300 \text{ (tpd)}} \times C \text{ (tpd)}$	$EM = \frac{\$232,850,000}{300 \text{ (tpd)}} \times C \text{ (tpd)}$
Air Separation Unit (ASU) ^b	$ASU = \$1.04 \times 10^6 \times \left(\frac{0}{10^6}\right)$	$\frac{.1426}{2.5}$ × C (tpd) + 19.983)
Haber-Bosch (HB) Reactor ^b	$\mathrm{HB} = \$1.04 \times 10^6 \times \left(\frac{0.33}{10^6}\right)$	$\frac{2023}{2.5}$ × C (tpd) + 28.438)
Purchased Equipment Cost (PEC) ^b	PEC = MVC +	EM + ASU + HB
Utilities and Balance of Plant (BoP) ^b	BoP = 0	$0.6 \times PEC$

Table S2. Major installed cost components for green ammonia production.

^a The installed costs of MVC and EM are approximated to be proportional to the production capacity (C) of 300 tons of ammonia per day (tpd), using Nosherwani and Neto (2021) as a reference. ^b The costs of ASU, HB reactor, and BoP are calculated based on data provided by Rivarolo *et al.* (2019).

Component	Formula	Description
Total Plant Cost (TPC)	$TPC = 120\% \times TIC$	Estimated contingency 20%.
Spare Parts Cost (SPC)	$SPC = 0.5\% \times TPC$	About 0.5% of total plant cost.
Start-up Cost (SUC)	$SUC = (2\% \times TPC) + (15\% \times M) +$	Modified start-up cost from IEAGHG (2017) to account for electricity usage (used
	$\frac{1}{12} \times (25\% \times \text{NG} + 3 \times \text{DL} + \text{CC} + 25\% \times \text{E})$	for green ammonia analysis), which comprised of: (i) 2% of total plant cost (TPC), (ii) 15% of maintenance cost (M), and (iii) one month usage of natural gas cost (NG) at 25% capacity testing, 3 months direct labor cost (DL), one month of chemical and catalyst cost (CC), one month usage of electricity cost (NG) at 25% capacity testing. All component costs are based on annual cost.
Owner's Cost (OC)	$OC = 7\% \times TPC$	Assumed to be 7% of the TPC. Owner's cost covers the expenditure related to the feasibility studies, land surveys, land purchase, construction or improvement to roads and railways, water supply, and other physical infrastructures.
Interest during Construction (IDC)	$IDC = DR \times TPC$	Interest rate assumed to be equal to discount rate (DR).
Working Capital	Gray and blue	Includes inventories of fuel and chemicals for one month.
(WC)	WC = $\frac{\text{NG} + \text{CC}}{12}$	
	Green	Assumed to be 7% of the total purchased equipment cost (PEC) (Rivarolo <i>et al.</i> 2019)
	$WC = 7\% \times PEC$	2019)
Total Capital Cost Requirement (TCR)	TCR = TPC + SPC + SUC + OC + IDC + WC	Total capital cost is the summation of all the cost components listed above.

Table S3. Summary of total capital cost requirement (IEAGHG, 2017).

Table S4. Components of the fixed operational cost.

Component	Formula	
Direct Labor (DL) ^a	$NL \times AS$	
Maintenance (M)	$1.5\% \times \text{TPC}$ (Gray and blue ammonia) ^a	
	$3\% \times \text{TPC}$ (Green ammonia) ^b	
Insurance and Local Taxes (ILT) ^a	$1\% \times \text{TPC}$	
Administration and General Overheads (AGO) ^a	$30\% \text{ x} (\text{DL} + 40\% \times \text{M})$	
Amortization (A) ^c	$\frac{45\% \times \text{EM}}{\text{EML}}$ (Green ammonia)	
Fixed Operation Cost (FOC)	FOC = DL + M + AGO + ILT + A	

^a IEAGHG (2017) where NL is number of direct laborers and AS is average salary, ^b Dias *et al.* (2020), ^c Used only for green ammonia calculation. The electrolyzer module cost (EM) is amortized based on the electrolyzer module lifetime (EML). The EML for alkaline electrolyzers and PEM electrolyzers is 10 years and 6 years, respectively (IRENA, 2020).

Table S5 . The amount of natural gas (NG) feedstock, natural gas fuel, electricity, and raw water needed for each of the ammoni
--

Parameters	Gray	Blue	Green (Alkaline)	Green (PEM)
NG Feedstock (ton NG/ton NH ₃)	0.57^{a}	0.57^{a}	0	0
NG Fuel (ton NG/ton NH₃)	0.22^{a}	0.22 ^{<i>a</i>}	0	0
Electricity (MWh/ton NH ₃)	0.186 ^{<i>a</i>}	0.365 ^{<i>a</i>}	9.274^b	9.869 ^c
Raw Feed and Process Water (m³/ton NH ₃)	0.393 ^{<i>a</i>}	0.073 ^{<i>a</i>}	2.697 ^c	2.697 ^c
Chemicals and Catalysts (\$/ton NH ₃)	$\frac{\$1,248,000}{1,350 \text{ (tpd)}} \times \text{C (tpd)}^d$	$\frac{\$_{1,248,000}}{1,350 (\text{tpd})} \times \text{C} (\text{tpd})^d$	$\frac{40\% \times \$1,248,000}{1,350 \text{ (tpd)}} \times \text{C} + 1\% \times TPC^{e}$	$\frac{40\% \times \$1,248,000}{1,350 (\text{tpd})} \times C^{e}$

^{*a*} adapted from IEAGHG (2017), ^{*b*} calculated from Guerra *et al.* (2020) and IRENA (2020), ^{*c*} adapted from Guerra *et al.* (2020), ^{*d*} proportionally calculated from IEAGHG (2017), ^{*c*} proportionally calculated from IEAGHG (2017), ^{*s*} chemicals and catalysts are for Haber-Bosch (HB) reactor and additional 1% of TPC is accounted for alkaline chemicals.

D. LCOA Results

Table S6. LCOA Calculation Details

Scenario	1	2	3-A	3-В	3-C	3-D
Ammonia type	Gray	Blue	Green	Green	Green	Green
Electricity source	Natural gas	Natural gas	Grid	Grid	Grid	Grid
Green electricity source	None	None	Hydro	Geothermal	Hydro	Geothermal
Grid electricity cost (\$/MWh)	0	0	45	60	45	60
Electrolyzer	-	-	Alkaline	Alkaline	PEM	PEM
Electricity (GJ/ton NH ₃)	0.67	1.32	33.38784	33.38784	35.5284	35.5284
NG feedstock (GJ/ton NH ₃)	26.51	26.51	0	0	0	0
NG fuel (GJ/ton NH ₃)	10.23	10.23	0	0	0	0
Electricity (GJ/yr)	439,927	867,634	21,935,811	21,935,811	23,342,159	23,342,159
NG Feed (GJ/yr)	17,413,785	17,413,785	-	-	-	-
NG Fuel (GJ/yr)	6,721,110	6,721,110	-	-	-	-
TOTAL ENERGY CONSUMPTION (GJ/yr)	24,574,822	25,002,529	21,935,811	21,935,811	23,342,159	23,342,159
Raw water (m³/yr)	258,128	47,888	1,771,929	1,771,929	1,771,929	1,771,929
CO_2e produced from onsite reformer (ton CO_2e/yr)	997,810	997,810	-	-	-	-
CO_2 produced from onsite boiler (ton CO_2e/yr)	794,875	842,351	-	-	-	-
CO_2e captured from onsite reformer (ton CO_2e/yr)	-	898,029	-	-	-	-
CO_2e captured from onsite boiler (ton CO_2e/yr)	-	758,115.55	-	-	-	-
CO_2e stored onsite (ton CO_2e/yr)	-	1,656,144	-	-	-	-
CO_2e released (ton CO_2e/yr)	1,792,685	184,016	-	-	-	-

Number of labor	66	71	55	55	55	55
CAPITAL COST (CAPEX)						
HB reactor	\$308,775,400	\$313,235,700	\$197,889,120	\$197,889,120	\$197,889,120	\$197,889,120
SMR	\$450,738,500	\$457,133,300	-	-	-	-
Electrolyzer modules	-	-	\$926,666,667	\$926,666,667	\$1,552,333,333	\$1,552,333,333
MVC	-	-	\$89,333,333	\$89,333,333	\$79,733,333	\$79,733,333
ASU	-	-	\$139,425,520	\$139,425,520	\$139,425,520	\$139,425,520
CO ₂ capture unit	-	\$71,644,444	-	-	-	-
CO ₂ compression unit	-	\$15,407,407	-	-	-	-
PEC (Purchased Equipment Cost)	\$759,513,900	\$857,420,852	\$1,353,314,640	\$1,353,314,640	\$1,969,381,307	\$1,969,381,307
Utilities and BoP	\$82,628,148	\$88,438,519	\$811,988,784	\$811,988,784	\$1,181,628,784	\$1,181,628,784
TIC (Total Installed Cost)	\$842,142,048	\$945,859,370	\$2,165,303,424	\$2,165,303,424	\$3,151,010,091	\$3,151,010,091
Contingency	\$168,428,410	\$189,171,874	\$433,060,685	\$433,060,685	\$630,202,018	\$630,202,018
TPC (Total Plant Cost)	\$1,010,570,458	\$1,135,031,244	\$2,598,364,109	\$2,598,364,109	\$3,781,212,109	\$3,781,212,109
Spare Parts Cost (SPC)	\$5,052,852	\$5,675,156	\$12,991,821	\$12,991,821	\$18,906,061	\$18,906,061
Start-up Cost (SUC)	\$26,740,720	\$29,980,631	\$66,744,854	\$66,744,854	\$93,559,326	\$93,559,326
Owner's Cost (OC)	\$70,746,064	\$79,452,187	\$181,885,488	\$181,885,488	\$264,684,848	\$264,684,848
Interest during Construction (IDC)	\$80,852,645	\$90,802,500	\$207,869,129	\$207,869,129	\$302,496,969	\$302,496,969
Working Capital (WC)	\$13,806,753	\$14,012,120	\$151,571,240	\$151,571,240	\$220,570,706	\$220,570,706
TCR (Total Capital Requirement)	\$1,208,200,795	\$1,354,953,838	\$3,067,296,170	\$3,067,296,170	4,681,430,018	\$4,681,430,018
OPERATING COST (OPEX)						
Direct labor (DL)	\$642,180	\$690,830	\$535,150	\$535,150	\$535,150	\$535,150
Maintenance (M)	\$15,158,557	\$17,025,469	\$77,950,923	\$77,950,923	\$113,436,363	\$113,436,363
Insurance & local Taxes (ILT)	\$10,105,705	\$11,350,312	\$25,983,641	\$25,983,641	\$37,812,121	\$37,812,121
Administration and general overheads (AGO)	\$2,011,681	\$2,250,305	\$9,514,656	\$9,514,656	\$13,772,909	\$13,772,909
Amortization (A)	-	-	\$41,700,000	\$41,700,000	\$116,425,000	\$116,425,000

Subtotal fixed operating cost	\$32,437,208	\$36,178,357	\$159,450,275	\$159,450,275	\$285,747,448	\$285,747,448
NG Feedstock and fuel (NG)	\$147,448,933	\$150,015,175	-	-	-	-
Electricity from grid (E)	-	-	\$274,197,636	\$365,596,848	\$291,776,985	\$389,035,980
Raw water	\$103,251	\$19,155	\$708,772	\$708,772	\$708,772	\$708,772
Chemicals & catalysts (CC)	\$1,848,889	\$1,848,889	\$26,723,197	\$26,723,197	\$739,556	\$739,556
CO ₂ capture	-	\$53,068,088	-	-	-	-
CO ₂ storage	-	\$17,886,360	-	-	-	-
CO_2 penalty	\$17,926,850	\$1,840,160	-	-	-	-
Subtotal variable operating cost	\$167,327,923	\$224,677,828	\$301,629,604	\$393,028,816	\$293,225,312	\$390,484,307
Total Operating Cost	\$195,246,046	\$255,994,744	\$457,313,974	\$548,713,186	\$575,206,855	\$672,465,850
LCOA	\$297	\$390	\$696	\$835	\$876	\$1,024

E. GHG Factor Calculation

The composition of flash gas produced from the steam methane reforming (SMR) unit for gray ammonia is gained from the reference Lee *et al.* (2022) as described in **Table S7**. The conversion equivalent factor to CO_2 is based on reference World Resource Institute (2023).

Table S7. Conversion calculation into CO_2 equivalent value for " CO_2 from aMDEA" stream from reference Lee et al. (2022)

	Mass (kg/kg NH ₃)	Mol fraction	Mass (kg/kg NH ₃)	CO ₂ equivalent factor	Carbon emission	Total carbon emission (kg CO2e/kg NH3)
CO ₂	1.32	0.97	1.298	1	1.298	1.403
CH ₄		0.01	0.005	21	0.105	
Ar		0.01	0.012	0	0	
H ₂ O		0.01	0.005	0	0	

References

- Dias, V., Pochet, M., Contino, F., and Jeanmart, H. (2020). Energy and economic costs of chemical storage. Frontiers in Mechanical Engineering 6, 21. <u>https://doi.org/10.3389/fmech.2020.00021</u>
- Guerra, C.F., Reyes-Bozo, L., Vyhmeister, E., and Caparros, M. (2020). Technical-economic analysis for a green ammonia production plant in Chile and its subsequent transport to Japan. Renewable Energy 157(10), 404-414. <u>https://doi.org/10.1016/j.renene.2020.05.041</u>
- IEAGHG. (2017). Techno-Economic Evaluation of Hyco Plant Integrated to Ammonia/Urea or Methanol Production with CCS. https://ieaghg.org/exco_docs/2017-03.pdf
- IRENA. (2020). Green hydrogen cost reduction: scaling up electrolyzers to meet the 1.5°C climate goal. International Renewable Energy Agency, Abu Dhabi.
- Lee, K., Liu, X., Vyawahare, P., Sun, P., Elgowainy, A., and Wanga, M. (2022) Techno-economic performances and life cycle greenhouse gas emissions of various ammonia production pathways including conventional, carbon-capturing, nuclear-powered, and renewable production. *Green Chemistry*, 24(12), 4830-4844. <u>https://doi.org/10.1039/D2GC00843B</u>
- Nosherwani, S.A., Neto, R.C. (2021). Techno-economic assessment of commercial ammonia synthesis methods in coastal areas of Germany. Journal of Energy Storage 34, 102201. <u>https://doi.org/10.1016/j.est.2020.102201</u>
- Rivarolo, M., Riveros-Godoy, G., Magistri, L., and Massardo, A. F. (2019) Clean Hydrogen and Ammonia Synthesis in Paraguay from the Itaipu 14 GW Hydroelectric Plant. *ChemEngineering*, *3*, 87. <u>http://dx.doi.org/10.3390/chemengineering3040087</u>

World Resources Institute. (2023). Climate Watch Historical GHG Emissions (1990-2020). Washington,

DC. https://databank.worldbank.org/metadataglossary/world-development-indicators/series/EN.ATM.METH.KT.CE.